



ARCHITECT BORHADE

MR. DATTATRYA A. BORHADE
MRS. RUPALI D. BORHADE
B. ARCHITECTURE

ARCHITECTS & INTERIOR DESIGNERS

Date: 31/12/2012

TO WHOM SO EVER IT MAY CONCERN

I hereby certify that the work of sewage disposal system at Jaihind Comprehensive Educational Institute's Institute of Technology, at Kuran, Tal. Junnar, Dist. Pune 410511, has been supervised by me & completed as per building norms.

Septic Tank of 2200 Cu. Mt. Provided. Single line system of Sewage Disposal is provided. Slop of 1:40 for Single line System and inspection chamber at 10 Mt. Centre to centre provided. Soak pit for Effluent is provided.

The work has been completed to my best satisfactions, the workmanship and all the materials (type & grade) have used strictly in accordance with the Act or the Building Rules.

Thanking you.

Ar. Dattatraya A. Borhade

Reg. No. : CA/25956/2000

